

Matt Lindquist

Manager Environmental Engineering

9701 Manchester • Houston, TX 77012-2408 713-923-3378 • Fax: 713-923-3561 matthew.lindquist@valero.com





Jeff Hude, P.E.
Director, Environmental, Health and Safety

9701 Manchester • Houston, TX 77012-2408 713-923-3478 • Fax: 713-923-3561 jeff.hude@valero.com

9820201

SAN PROTECTOR

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6 1445 ROSS AVENUE, SUITE 1200 DALLAS, TX 75202-2733

November 2, 2017

Matthew Lindquist Valero Refining - Texas LP 9701 Manchester Street Houston, TX 77012

RE: Houston Refinery, FRP-06-TX-00155

Dear Mr. Lindquist:

This letter is to notify you that the United States Environmental Protection Agency (EPA) has approved your Facility Response Plan. All appropriate liability requirements set forth in the Clean Water Act (CWA) 311(j)(5), as amended by the Oil Pollution Act of 1990 are still applicable. This regulatory approval was based upon technical review of the plan submissions. Please be advised that EPA will continue to monitor your facility's approval status through site inspections and information validation.

If EPA determines during its next review, or during field verification, that the response plan is inadequate, or if EPA acquires information which indicates your response plan is inadequate to manage potential discharges, EPA will require appropriate revisions to your plan. Failure to make such revisions may affect your plan's approved status.

If you have any questions concerning this letter, please contact my office at 214-665-6702.

Sincerely,

Bryant Smalley

Oil Spill & Response Team Leader,

USEPA R6 (SF-EO)

Federal On-Scene Coordinator

(214) 665-7368 (office)

ENVIRONMENTAL FILING FORM

CIRCLE ONE: NEW FILE	>
----------------------	---

OR

INFILING

OIL POLLUTION ACT - ENFORCEMENT DOCKETS

48474/

SITE NAME	Valero Refining - Texas LP / Houston Refinery
SITE ADDRESS INSPECTOR	9701 Manchester Street, Harris County, TX 77012
FACILITY ID/DOCKET NUMBER	R6-TX-00155/ Cwanton 2017-
RESPONSIBLE PARTY	Chris Perry (6SF-EO) (Person bringing this material to the Records Center.)
TELEPHONE NUMBER	5-6702
SPECIAL INSTRUCTIONS	FY-2017 / Insp. #:FRP-TX-2017-00076



NOTICE OF SPCC/FRP INSPECTION

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 6

				النظالية		
Date:	Date: 4 4 17 FRP Inspection Number: SPCC Inspection Number: 5PCC-Tx-2017-77					
Lead	Inspector (Print Nan	ne & Sign): Ch	iris Perry	3_		
Addit	ional Inspectors:			7		
Facili	ty Name:	1 agus	Facility Address:	0-5/1	level Tv	Facility Type: Retinery
Facili	ty Phone:		970 Manchoste Facility Email: matt.lindqui	, <u>, , , , , , , , , , , , , , , , , , </u>	toosion 1x	Facility Fax:
1	13-923-33	78	matt.lindqui	stev	ilero.can	Facility Fax: 7 13 -9 d 3 - 35 6 l
Prevent to, revi	tion regulations found at ewing and obtaining copi	40 C.F.R. Part 112 ies of documents ar	(the "Regulations"). The scope	e of the inspe y personnel;	ection and plan review pro a physical inspection of the	U.S.C. § 1321, and the Oil Pollution poess may include, but is not limited the facility (including process areas); and the regulations.
			n ("Notice") carefully Note that bservations and not a determina			pector and communicated to you
Penalti States I penalti review	Please be advised that any noncompliance with the Regulations may constitute a violation under the Act for which penalties or other relief may be sought. Penalties may be assessed upon subsequent findings by the Administrator or a court that the facility has violated the Act and/or the regulations. The United States Environmental Protection Agency ("EPA") reserves its right to initiate an enforcement action under the Act and any other applicable law, to seek penalties and other appropriate relief, for any violation of the Act, the Regulations, or such other laws. This Notice and other relevant information will be reviewed by appropriate EPA personnel to determine if any deficiencies, identified in such review, constitute violations of the Act and the Regulations and whether an enforcement action is appropriate. EPA will provide written correspondence describing any deficiencies identified during the inspection.					
			d during the inspection and com s you submit all information, as			conference you are urged to correct prection of the deficiencies to:
	Chris Perry U.S. Environmental Protection Agency Perry.chris@epa.gov					
by whe	If it is not feasible to correct the deficiencies within 30 days of the date of the inspection, immediately submit a detailed explanation and schedule indicating by when the noted deficiencies will be corrected. If you believe that your facility is not required to have an SPCC and/or FRP Plan, or is in compliance with the SPCC and FRP regulatory requirements, submit an explanation, supported by documentation, as to why the facility is not subject to the SPCC and/or FRP provision of the Oil Pollution Prevention regulations at 40 C.F.R Part 112 or meets its requirements within 30 days of the date of the inspection.					or FRP Plan, or is in compliance with is not subject to the SPCC and/or FRP
		•	Confidential Busine	ess Informat	tion	
C.F.R.	For the information submitted to EPA, you may be entitled to claim it as Confidential Business Information (CBI) pursuant to the regulations set forth in 40 C.F.R. Part 2. If EPA determines the information you have designated meets the criteria in 40 C.F.R. § 2.208, the information will be disclosed only to the extent and by means of the procedures specified in 40 C.F.R. Part 2 Subpart B. Unless CBI is claimed, EPA may make the information available to the public without further notice to you.					
			Acknowledgemen	t of Insp	ection	
Signs	ture of Facility Re	presentative:)	=		
	lean of	udsal				
Name	e & Title of Faculty	Representati		_	1.	
11	ATTOCAL LIA	JUST	-/ Engan	.1 2	emerny M	lanases

FACILITY INFORMATION			
FACILITY NAME: HOUS fon	Refinery		
LATITUDE: 19,718889 L	^	53889 GPS DA	ATUM: Google Earth
Section/Township/Range:		TABASE ID: ALG-LI	A-155 ICIS#:
ADDRESS: 9701 Manches	ster St		
CITY: Houston	STATE: TX	ZIP: 77016	2 COUNTY: HERRIS
MAILING ADDRESS (IF DIFFERENT FROM FACIL		7):	
Same P.O Box	5038	_	
city: Houston	STATE: TK	ZIP: 77262	COUNTY: Harris
TELEPHONE: 713-923-3506	FACILITY CONTACT	T NAME/TITLE: Ma	Athew-Linguist -
OWNER NAME: Valero	Rofining- Te	exas Lopo	
OWNER ADDRESS: P.O. Box	500		
CITY: San Antonio	STATE: TX	ZIP: 7821)	COUNTY:
TELEPHONE:	FAX:	E	MAIL: matt. Lindgoist @ valero.co
FACILITY OPERATOR NAME (IF DIFFERENT	FROM OWNER - IF NOT, PRINT "SAM		
OPERATOR ADDRESS:			
CITY:	STATE:	ZIP:	COUNTY:
TELEPHONE:	OPERATOR CONTA	ACT NAME/TITLE:	
FACILITY TYPE: Letiner	`U		NAICS CODE: 324110
HOURS PER DAY FACILITY ATTENDED		TOTAL FACILITY C	APACITY: 209, 229 464 9al
TYPE(S) OF OIL STORED: Casoli	re ret fuel:	diesel, crui	de, No. 6 feel oil
LOCATED IN INDIAN COUNTRY?	-	•	
INERECTION/ALANTREVIEW INFOR	RMATION		
PLAN REVIEW DATE: 3/80/13	REVIEWER NAME		
INSPECTION DATE: 4/4/17	TIME: 0830	ACTIVITY ID NO	D: SPCC-TX-2017- 77
LEAD INSPECTOR: Chris Perry	***************************************		FRP- Tro
OTHER INSPECTOR(S):		•	·
INSPECTION FACKNOWLEDGMENT			
I performed an SPCC inspection at the fa	acility specified above.		
INSPECTOR SIGNATURE:	5/		DATE:
SUPERVISOR REVIEW/SIGNATURE:			DATE:

SPCC GENERAL APPLICABILITY—40 CFR 112.1	the Control of the Co		
IS THE FACILITY REGULATED UNDER 40 CFR part 112?			
The completely buried oil storage capacity is over 42,000 U.S. gallons, oil storage capacity is over 1,320 U.S. gallons AND	Plyes I No		
The facility is a non-transportation-related facility engaged in drilling, pr processing, refining, transferring, distributing, using, or consuming oil a location could reasonably be expected to discharge oil into or upon the States	and oil products, which due to its		
AFFECTED WATERWAY(S):	DISTANCE:		
FLOW PATH TO WATERWAY:	11 1 4 6		
The facility is located alon Channel.	g the Houston 5h%		
Crocrivier.			
Note: The following storage capacity is not considered in determining applicability of	·		
Transportation, U.S. Department of the Interior, or Minerals	Containers smaller than 55 U.S. gallons;		
Management Service, as defined in Memoranda of Understanding dated November 24, 1971, and November 8, 1993: Tank trucks that ratum to	Permanently closed containers (as defined in §112.2);		
an otherwise regulated facility that contain only residual amounts of oil	Motive power containers(as defined in §112.2);		
Completely buried tanks subject to all the technical requirements of 40	Hot-mix asphalt or any hot-mix asphalt containers; Heating oil containers used solely at a single-family residence;		
or repair 200 or a state program approved under 40 or repair 201;	Pesticide application equipment and related mix containers;		
supply emergency diesel generators at a nuclear power generation	Any milk and milk product container and associated piping and		
subject to any NAC provision regarding design and quality criteria,	appurtenances; and		
	Intra-facility gathering lines subject to the regulatory requirements		
Any facility or part thereof used exclusively for wastewater treatment (production, recovery or recycling of oil is not considered wastewater treatment); (This does not include other oil containers located at a wastewater treatment facility, such as generator tanks or transformers)	of 49 CFR part 192 or 195.		
Does the facility have an SPCC Plan?	<u></u> ✓Yes ∐No		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11	2.20(f)		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and impl The facility transfers oil over water to or from vessels and has a total	2.20(f) lement an FRP as outlined in 40 CFR 112.20 if:		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and impl The facility transfers oil over water to or from vessels and has a tota 42,000 U.S. gallons, OR	2.20(f) lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to		
A non-transportation related onshore facility is required to prepare and implementation under the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S.	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true:		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implementation of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation.	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and impl The facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. The facility does not have secondary containment sufficient	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and impl The facility transfers oil over water to or from vessels and has a tota 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. The facility does not have secondary containment sufficient tank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge of the secondary containment sufficient freeboard for precipitation.	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. The facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge cenvironments.	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntiy large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake.		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implementation of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient tank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge cenvironments. The facility is located such that a discharge would shut do	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntiy large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake.		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement that the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. The facility does not have secondary containment sufficient tank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge environments. The facility is located such that a discharge would shut do The facility has had a reportable discharge greater than or	lement an FRP as outlined in 40 CFR 112.20 if: al oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive nwn a public drinking water intake. r equal to 10,000 U.S. gallons in the past 5 years.		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient tank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge environments. The facility is located such that a discharge would shut does not have secondary containment sufficient tank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge would shut does not have a discharge would shut does not have a such that a discharge would shut does not have a discharge would shut does not have a discharge greater than of the facility has FRP: Yes No No	dement an FRP as outlined in 40 CFR 112.20 if: all oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake. The equal to 10,000 U.S. gallons in the past 5 years. FRP Number: FRP-06-Ty - 00 [55]		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge denvironments. The facility is located such that a discharge would shut does not have a reportable discharge greater than one facility has FRP: Yes No NA Facility has a completed and signed copy of Appendix C, Attachment C-II, "Certification of the Applicability of the Substantial Harm Criteria."	dement an FRP as outlined in 40 CFR 112.20 if: all oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake. The equal to 10,000 U.S. gallons in the past 5 years. FRP Number: FRP-06-Ty - 00 [55]		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge denvironments. The facility is located such that a discharge would shut does not have a reportable discharge greater than one facility has FRP: Yes No NA Facility has a completed and signed copy of Appendix C, Attachment C-II, "Certification of the Applicability of the Substantial Harm Criteria."	dement an FRP as outlined in 40 CFR 112.20 if: all oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake. The equal to 10,000 U.S. gallons in the past 5 years. FRP Number: FRP-06-Ty - 00 [55]		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge denvironments. The facility is located such that a discharge would shut does not have a reportable discharge greater than one facility has FRP: Yes No NA Facility has a completed and signed copy of Appendix C, Attachment C-II, "Certification of the Applicability of the Substantial Harm Criteria."	dement an FRP as outlined in 40 CFR 112.20 if: all oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake. The equal to 10,000 U.S. gallons in the past 5 years. FRP Number: FRP-06-Ty - 00 [55]		
FACILITY RESPONSE PLAN (FRP) APPLICABILITY—40 CFR 11 A non-transportation related onshore facility is required to prepare and implement of the facility transfers oil over water to or from vessels and has a total 42,000 U.S. gallons, OR The facility has a total oil storage capacity of at least 1 million U.S. of the facility does not have secondary containment sufficient trank plus sufficient freeboard for precipitation. The facility is located at a distance such that a discharge denvironments. The facility is located such that a discharge would shut does not have a reportable discharge greater than one facility has FRP: Yes No NA Facility has a completed and signed copy of Appendix C, Attachment C-II, "Certification of the Applicability of the Substantial Harm Criteria."	dement an FRP as outlined in 40 CFR 112.20 if: all oil storage capacity greater than or equal to gallons, AND at least one of the following is true: ntly large to contain the capacity of the largest aboveground could cause injury to fish and wildlife and sensitive own a public drinking water intake. The equal to 10,000 U.S. gallons in the past 5 years. FRP Number: FRP-06-Ty - 00 [55]		

SPCC TIER II	QUALIFIED FACILITY APPLICABILIT	Y—40 (CFR 112.3(g)(2)		
In the three year	boveground oil storage capacity is 10,000 s prior to the SPCC Plan self-certification d in operation for less than three years), the	late, or si	nce becoming subject	to the rule (if the	Yes No
	harge as described in §112.1(b) exceeding				Yes No
	ges as described in §112.1(b) each exceeding			welve-month period ¹	Yes No
	IF YES TO ALL OF THE ABOVE, TH SEE ATTACHMENT D FO				ITY ²
REQUIREMEN	ITS FOR PREPARATION AND IMPLE	MENTA	ATION OF A SPCC	PLAN-40 CFR 11	2.3
Date facility beg	an operations: 1940				
Date of initial SF	PCC Plan preparation:	Current	Plan version (date/nu	mber): March	2017
112.3(a)	For facilities (except farms), including in operation on or prior to November implemented by November 10, 2011 Beginning operations after November before beginning operations	10, 2011	: Plan prepared and/o		Yes No NA
For farms (as defined in §112.2): In operation on or prior to August 16, 2002: Plan maintained, amended and implemented by May 10, 2013 Beginning operations after August 16, 2002 through May 10, 2013: Plan prepared and fully implemented by May 10, 2013				Yes No No NA Yes No No NA	
112.3(d)	Plan is certified by a registered Profession PE attests: PE is familiar with the requirements of PE or agent has visited and examined. Plan is prepared in accordance with of applicable industry standards and Procedures for required inspections. Plan is adequate for the facility.	of 40 CF ed the fac good end the requ	R part 112 cility gineering practice incluirements of 40 CFR pa	uding consideration art 112	Yes No NA
PE Name: Ra	Iph Chaiet License No.: 751	101	State: 1x	Date of certification	1: 3/3/15
112.3(e)(1)		ast 4 hou			Yes No NA
Comments:					

¹ Oil discharges that result from natural disasters, acts of war, or terrorism are not included in this determination. The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.

² An owner/operator who self-certifies a Tier II SPCC Plan may include environmentally equivalent alternatives and/or secondary containment impracticability determinations when reviewed and certified by a PE.

AMENDMENT	OF SPCC PLAN BY REGIONAL ADMINISTRATOR (RA)-40 GFR 112.4	
112.4(a),(c)	Has the facility discharged more than 1,000 U.S. gallons of oil in a single reportable discharge or more than 42 U.S. gallons in each of two reportable discharges in any 12-month period?	Yes No
If YES	 Was information submitted to the RA as required in §112.4(a)?⁴ Was information submitted to the appropriate agency or agencies in charge of oil pollution control activities in the State in which the facility is located§112.4(c) Date(s) and volume(s) of reportable discharges(s) under this section: 	Yes No ANA
	Were the discharges reported to the NRC ⁵ ?	☐Yes ☐No
112.4(d),(e)	Have changes required by the RA been implemented in the Plan and/or facility?	TY00 INO INA
Comments:		
AMENDMENT	OF SPCC PLAN BY THE OWNER OR OPERATOR—40 GFR 112:5	
112.5(a)	Has there been a change at the facility that materially affects the potential for a discharge described in §112.1(b)?	Yes I No
If YES	Was the Plan amended within six months of the change?	Yes No
	Were amendments implemented within six months of any Plan amendment?	Yes No
112.5(b)	Review and evaluation of the Plan completed at least once every 5 years? ' Following Plan review, was Plan amended within six months to include more effective prevention and control technology that has been field-proven to significantly reduce the likelihood of a discharge described in §112.1(b)? Amendments implemented within six months of any Plan amendment?	Yes No NA Yes No ZNA
	Five year Plan review and evaluation documented?	Yes No NA
112.5(c)	Professional Engineer certification of any technical Plan amendments in accordance with all applicable requirements of §112.3(d) [Except for self-certified Plans]	Yes No ZNA
Name: Eric	Politie License No.: 77962 State: Tx Date of certification:	12/30/15
Reason for ame	ndment: Installation of 2 tanks and new pipe	•
Comments:	·	
•	•	
		•
	•	
1		•

³ A reportable discharge is a discharge as described in §112.1(b)(see 40 CFR part 110). The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil

⁴ Triggering this threshold may disqualify the facility from meeting the Qualified Facility criteria if it occurred in the three years prior to self certification ⁵ Inspector Note-Confirm any spills identified above were reported to NRC

ENERALISI	ece requiren	MENTS 40 CFR	112.7		PLAN		FIELD
anagement ap Illy implement	pproval at a level of the Plan ⁶	of authority to comn	mit the necessary resources to	Ye	s No		
lan follows sec quirements a	quence of the rule nd includes a cros	or is an equivalent ss-reference of prov	t Plan meeting all applicable rul risions	e Z Ye	s No 🗆	NA	
etails of their i	facilities, procedur nstallation and sta testing baselines.)	art-up are discussed	quipment not yet fully operational discrete Relevant for Inspection	al, Ye	s 🔲 No 🗹	ŅA	
112.7(a)(2)	(h)(2) and (3), a	nd (i) and applicable	the requirements of §§112.7(g), le subparts B and C of the rule, requirements in §§112.7(c) and		s No 🗸	NA .	
	(h)(1), 112.8(c)((2),112.8(c)(11), 112	2.12(c)(2), and 112.12(c)(11)		. D., 6	1	
If YES		ates reasons for no			s No	_	
	environmen the environi	ntal protection (Note	d in detail and provide equivale e: Inspector should document if e is implemented in the field, in scription)	''' Ye	s □No ፱	NA LIYes	□No ☑N
escribe each	deviation and reas	sons for nonconform	nance:			······································	
		•					
	•	-					
	•						
	•						
	•						
					,		
,		•					
		·			•		
					,		
		. ·					
			••				
		•					
		•	•				
•	·					•	
		•					

⁶ May be part of the Plan or demonstrated elsewhere. Onshore Facilities (Excluding Oil Production)

		/ PLAN	FIELD
110 7/0\/2\	Discrete subscribed lessons of feelility and includes a discrete.		
112.7(a)(3)	Plan describes physical layout of facility and includes a diagram that identifies: Location and contents of all regulated fixed oil storage containers	☑Yes ☐No	✓ Yes □ No
·	Storage areas where mobile or portable containers are located		
	Completely buried tanks otherwise exempt from the SPCC requirements (marked as "exempt")		
	Transfer stations		•
	 Connecting pipes, including intra-facility gathering lines that are otherwise exempt from the requirements of this part under §112.1(d)(11) 	<u> </u>	
·	Plan addresses each of the following:		
(1)	For each fixed container, type of oil and storage capacity (see Attachment A of this checklist). For mobile or portable containers, type of oil and storage capacity for each container or an estimate of the potential number of mobile or portable containers, the types of oil, and anticipated storage capacities	ØYes □No	☑Yes □No
(ii)	Discharge prevention measures, including procedures for routine handling of products (loading, unloading, and facility transfers, etc.)	Yes No	☑Yes □No
(III)	Discharge or drainage controls, such as secondary containment around containers, and other structures, equipment, and procedures for the control of a discharge	Yes No	☑Yes ☐No
(iv)	Countermeasures for discharge discovery, response, and cleanup (both facility's and contractor's resources)	ØYes □No	₩Yes □No
(v)	Methods of disposal of recovered materials in accordance with applicable legal requirements	Yes No	
(vi)	Contact list and phone numbers for the facility response coordinator, National Response Center, cleanup contractors with an agreement for response, and all Federal, State, and local agencies who must be contacted in the case of a discharge as described in §112.1(b)	Yes No	
112.7(a)(4)	Page not apply if the facility has submitted an EDD under \$440.00.	Yes No NA	
	Does not apply if the facility has submitted an FRP under §112.20: Plan includes information and procedures that enable a person report an oil discharge as described in §112.1(b) to relate information on the:	ring	
	Exact address or location and phone Description of all af number of the facility; Cause of the discharge.	<u>-</u>	
		s caused by the discharge;	
		to stop, remove, and	
	Estimates of the total quantity discharged; mitigate the effects o Estimates of the quantity discharged as Whether an evacua	it the discharge; ition may be needed; and	
	demands and the Odd Odd N.S.	Is and/or organizations who	
	Source of the discharge; have also been conti		
112.7(a)(5)	Does not apply if the facility has submitted a FRP under §112.20:	Yes No INA	
	Plan organized so that portions describing procedures to be used when a discharge occurs will be readily usable in an emergency		
112.7(b)	Plan includes a prediction of the direction, rate of flow, and total quantity of oil that could be discharged for each type of major equipment failure where experience indicates a reasonable potential for equipment failure	MYes □No □NA	
Comments:		•	
	•		
			•
•			
	,		

⁷ Note in comments any discrepancies between the facility diagram, the description of the physical layout of facility, and what is observed in the field Onshore Facilities (Excluding Oil Production)

Page 7 of 14

December 2012 (12-10-12)

·		PLAN	FIELD
112.7(c)	Appropriate containment and/or diversionary structures or equipment a in §112.1(b), except as provided in §112.7(k) of this section for cerentire containment system, including walls and floors, are capable of cescape of a discharge from the containment system before cleanup oc secondary containment address the typical failure mode and the most See Attachment A of this checklist.	tain qualified operation on taining oil and are corcurs. The method, designers.	nal equipment. The astructed to prevent and capacity for
	For onshore facilities, one of the following or its equivalent:		
	/ impervious to contain oil; • Spill diversit	ns or other barriers; on pond;	
•	Curbing or drip pans; Retention possible Sumps and collection systems; Sorbent ma		
	Sumps and collection systems; Culverting, gutters or other drainage systems;	terials	· · · · · · · · · · · · · · · · · · ·
•	Identify which of the following are present at the facility and if appropria equipment are provided as described above:	ate containment and/or	diversionary structures
,	Bulk storage containers	Yes No NA	Zyes No No
elooard=	Mobile/portable containers	ZY9S NO NA	Yes No No
o pocro	Oil-filled operational equipment (as defined in 112.2)	Yes DNo DNA	
u	Other oil-filled equipment (i.e., manufacturing equipment)	☐Yes ☐No ☑NA	
10"			
	Piping and related appurtenances		
	Mobile refuelers or non-transportation-related tank cars	Yes No NA	
	✓ Transfer areas, equipment and activities	Yes No NA	✓ Yes No 1
	ldentify any other equipment or activities that are not listed above:	Yes No ZNA	Yes No Zi
112.7(d)	Secondary containment for one (or more) of the following provisions is determined to be impracticable:	☐Yes ☑No	
•	General secondary containment \$\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\	·	
,	Loading/unloading rack Mobile/portable containers§§112.8(c)(11)/ 112.12(c)(11)		
if YES	 The impracticability of secondary containment is clearly demonstrated and described in the Plan 	Yes No ZNA	Yes No 🗹
	 For bulk storage containers,⁸ periodic integrity testing of containers and integrity and leak testing of the associated valves and piping is conducted 	Yes No MA	Yes No Z
	 (Does not apply if the facility has submitted a FRP under §112.20): Contingency Plan following the provisions of 40 CFR part 109 is provided (see Attachment C of this checklist) AND 	☐Yes ☐No ☑NA	
	Written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful	□Yes □No ☑NA	Yes No E
Comments	discharged that may be harmidi	<u> </u>	
Comments:			
1,			

⁶ These additional requirements apply only to bulk storage containers, when an impracticability determination has been made by the PE

Onshore Facilities (Excluding Oil Production) Page 8 of 14 December 2012 (12-10-12)

		PLAN	FIELD
112.7(e)	Inspections and tests conducted in accordance with written procedures	Yes No	₩Yes □ No
1/1/4	Record of inspections or tests signed by supervisor or inspector	Yes DNo	☑Yes □No
no,	Kept with Plan for at least 3 years (see Attachment B of this checklist) ⁹	Yes No	☑ Yes ☐ No
112.7(f)	Personnel, training, and oil discharge prevention procedures	<u>.</u>	
(1)	Training of oil-handling personnel in operation and maintenance of equipment to prevent discharges; discharge procedure protocols; applicable pollution control laws, rules, and regulations; general facility operations; and contents of SPCC Plan		Øyes □No □NA
(2)	Person designated as accountable for discharge prevention at the facility and reports to facility management	Yes No NA	ØYes □No □NA
(3)	Discharge prevention briefings conducted at least once a year for oil handling personnel to assure adequate understanding of the Plan. Briefings highlight and describe known discharges as described in §112.1(b) or fallures, malfunctioning components, and any recently developed precautionary measures	Yes No NA	ØYes □No □NA
112.7(g)	Plan describes how to: Secure and control access to the oil handling, processing and storage areas; Secure master flow and drain valves; Prevent unauthorized access to starter controls on oil pumps; Secure out-of-service and loading/unloading connections of oil pipelines; and Address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges.	Yes ONO ONA	ØYes □ No □ NA
112.7(h)	Tank car and tank truck loading/unloading rack ¹⁰ is present at the facil	lity	Yes VNo
	Loading/unloading rack means a fixed structure (such as a platform, gangway) car, which is located at a facility subject to the requirements of this part. A load and may include any combination of the following: piping assemblages, valves, safety devices.	necessary for loading or unling/unloading rack includes	a loading or unloading arm,
If YES (1)	Does loading/unloading rack drainage flow to catchment basin or treatment facility designed to handle discharges or use a quick drainage system?	Yes No MA	Yes No MA
	Containment system holds at least the maximum capacity of the largest single compartment of a tank car/truck loaded/unloaded at the facility	Yes No ZNA	Yes No MA
(2)	An interlocked warning light or physical barriers, warning signs, wheel chocks, or vehicle brake interlock system in the area adjacent to the loading or unloading rack to prevent vehicles from departing before complete disconnection of flexible or fixed oil transfer lines	Yes No MA	Yes No ZNA
(3)	Lower-most drains and all outlets on tank cars/trucks inspected prior to filling/departure, and, if necessary ensure that they are tightened, adjusted, or replaced to prevent liquid discharge while in transit	Yes No 🗓 NA	Yes No I NA
Comments:			<u> </u>
			-
	•		

⁹ Records of inspections and tests kept under usual and customary business practices will suffice ¹⁰ Note that a tank car/truck loading/unloading rack must be present for §112.7(h) to apply

		PLAN	/ FIELD
112.7(i)	Brittle fracture evaluation of field-constructed aboveground containers is conducted after tank repair, alteration, reconstruction, or change in service that might affect the risk of a discharge or after a discharge/failure due to brittle fracture or other catastrophe, and appropriate action taken as necessary (applies to only field-constructed aboveground containers)	Yes No NA	Yes No NA
112.7(j)	Discussion of conformance with applicable more stringent State rules, regulations, and guidelines and other effective discharge prevention and containment procedures listed in 40 CFR part 112	Yes No NA	
112.7(k)	Qualified oil-filled operational equipment is present at the facility ¹¹		Yes No
If YES	Oil-filled operational equipment means equipment that includes an oil storage of present solely to support the function of the apparatus or the device. Oil-filled container, and does not include oil-filled manufacturing equipment (flow-throug equipment include, but are not limited to, hydraulic systems, lubricating system rotating equipment, including pumpjack lubrication systems), gear boxes, mach transformers, circuit breakers, electrical switches, and other systems containing Check which apply:	pperational equipment is not h process). Examples of oil- s (e.g., those for pumps, co	considered a bulk storage filled operational mpressors and other
	Secondary Containment provided in accordance with 112.7(c)		
	Alternative measure described below (confirm eligibility)		
112.7(k)	 Qualified Oil-Filled Operational Equipment Has a single reportable discharge as described in §112.1(b) from operational equipment exceeding 1,000 U.S. gallons occurred with prior to Plan certification date? 	any oil-filled hin the three years	Yes No NA
	 Have two reportable discharges as described in §112.1(b) from an operational equipment each exceeding 42 U.S. gallons occurred a period within the three years prior to Plan certification date?¹² 	ny oil-filled vithin any 12-month	Yes No NA
	If YES for either, secondary containment in accord	ance with §112.7(c) is red	quired
	 Facility procedure for inspections or monitoring program to detect equipment failure and/or a discharge is established and documented 	Yes No PNA	Yes No NA
	 Does not apply if the facility has submitted a FRP under §112.20: Contingency plan following 40 CFR part 109 (see Attachment C of this checklist) is provided in Plan AND Written commitment of manpower, equipment, and materials 	Yes No NA	
	required to expeditiously control and remove any quantity of oil discharged that may be harmful is provided in Plan	LIYES LINO LINA	
Comments:	granding so national to provided in Figure		

¹¹ This provision does not apply to oil-filled manufacturing equipment (flow-through process)
12 Oil discharges that result from natural disasters, acts of war, or terrorism are not included in this determination. The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.

ONSHORE FA 40 CFR 112.8	CILITIES (EXCLUDING PRODUCTION)	PLAN	FIELD
112.8(b)/ 112.12	2(b) Facility Drainage	_	
Diked Areas (1)	Preinage from diked storage areas is: Restrained by valves, except where facility systems are designed to control such discharge, OR	Yes No NA	ØYes □No □NA
	Manually activated pumps or ejectors are used and the condition of the accumulation is inspected prior to draining dike to ensure no oil will be discharged		
(2)	Diked storage area drain valves are manual, open-and-closed design (not flapper-type drain valves)	Yes No NA	ØYes □No □NA
70	If drainage is released directly to a watercourse and not into an onsite wastewater treatment plant, retained storm water is inspected and discharged per §§112.8(c)(3)(ii), (iii), and (iv) or §§112.12(c)(3)(ii), (iii), and (iv).	Yes No NA	☑Xes □No □NA
Undiked Areas (3)	Drainage from undiked areas with a potential for discharge designed to flow into ponds, lagoons, or catchment basins to retain oil or return it to facility. Catchment basin located away from flood areas. 13	☐Yes ☐No ☑NA	
(4)	If facility drainage not engineered as in (b)(3) (i.e., drainage flows into ponds, lagoons, or catchment basins) then the facility is equipped with a diversion system to retain oil in the facility in the event of an uncontrolled discharge. ¹⁴		ØYes □No □NA
(5)	Are facility drainage waters continuously treated in more than one treatment unit and pump transfer is needed?	Yes No ZNA	Yes No MA
If YES	Two "lift" pumps available and at least one permanently installed	Yes No NA	Yes No ZNA
	 Facility drainage systems engineered to prevent a discharge as described in §112.1(b) in the case of equipment failure or human error 	Yes No 2/NA	Yes No ZNA
Comments:			
	·		
		•	
		,	
	•		
Bulk storage c prior to use, w storage contain	c(c) Bulk Storage Containers container means any container used to store oil. These containers are used for public being used, or prior to further distribution in commerce. Oil-filled electrical, opner. containers are not present, mark this section Not Applicable (NA). If present, containers	perating, or manufacturing e	quipment is not a bulk
(1)	Containers materials and construction are compatible with material stored and conditions of storage such as pressure and temperature	Yes No NA	ØYes ☐No ☐NA
(2)	Except for mobile refuelers and other non-transportation-related tank trucks, construct all bulk storage tank installations with secondary containment to hold capacity of largest container and sufficient freeboard for precipitation	Yes No NA	Yes No NA
10"	Diked areas sufficiently impervious to contain discharged oil OR Alternatively, any discharge to a drainage trench system will be safely confined in a facility catchment basin or holding pond	Yes No NA	Yes No No NA

Oil discharges that result from natural disasters, acts of war, or terrorism are not included in this determination. The gallon amount(s) specified (either 1,000 or 42) refers to the amount of oil that actually reaches navigable waters or adjoining shorelines not the total amount of oil spilled. The entire volume of the discharge is oil for this determination.
 These provisions apply only when a facility drainage system is used for containment; otherwise mark NA

			PLAN	FIELD
	(3)	Is there drainage of uncontaminated rainwater from diked areas into a storm drain or open watercourse?	Yes No NA	/
	If YES	Bypass valve normally sealed closed	Yes No NA	Yes No NA
	No. 2	Retained rainwater is inspected to ensure that its presence will not cause a discharge as described in §112.1(b)	Yes No NA	
		Bypass valve opened and resealed under responsible supervision	Yes No NA	Yes No NA
		 Adequate records of drainage are kept; for example, records required under permits issued in accordance with 40 CFR §§122.41(j)(2) and (m)(3) 	Yes No NA	Yes No NA
	(4)	For completely buried metallic tanks installed on or after January 10, 1974 (if not exempt from SPCC regulation because subject to all of the technical requirements of 40 CFR part 280 or 281):		
		 Provide corrosion protection with coatings or cathodic protection compatible with local soil conditions 	Yes No NA	Yes No NA
		Regular leak testing conducted	Yes No NA	Yes No NA
	(5)	The buried section of partially buried or bunkered metallic tanks protected from corrosion with coatings or cathodic protection compatible with local soil conditions	Yes No PNA	
pec	AP/652	Test or inspect each aboveground container for integrity on a regular schedule and whenever you make material repairs. Techniques include, but are not limited to: visual inspection, hydrostatic testing, radiographic testing, ultrasonic testing, acoustic emissions testing, or other system of non-destructive testing	Yes No NA	
	015	 Appropriate qualifications for personnel performing tests and inspections are identified in the Plan and have been assessed in accordance with industry standards 	Yes No NA	Yes No NA
	10+ 15-10	The frequency and type of testing and inspections are documented, are in accordance with industry standards and take into account the container size, configuration and design	Yes No NA	Yes No NA
		Comparison records of aboveground container integrity testing are maintained	Yes No NA	,
		Container supports and foundations regularly inspected	Yes No NA	Yes No NA
		Outside of containers frequently inspected for signs of deterioration, discharges, or accumulation of oil inside diked areas	Yes No NA	Yes No NA
		Records of all inspections and tests maintained 15	Yes No NA	Yes No NA
	Integrity Testing	Standard identified in the Plan:		
	112.12 (c)(6)(ii)	Conduct formal visual inspection on a regular schedule for bulk storage containers that meet all of the following conditions:	Yes No NA	Yes No NA
	(Applies to AFVO Facilities only)	 Subject to 21 CFR part 110; Have no external insulation; and Shop-fabricated. 		
		In addition, you must frequently inspect the outside of the container for signs of deterioration, discharges, or accumulation of oil inside diked areas.	☐Yes ☐No ☑NA	☐Yes ☐No ☑NA
		You must determine and document in the Plan the appropriate qualifications for personnel performing tests and inspections. 16	Yes No NA	Yes No NA

Records of inspections and tests kept under usual and customary business practices will suffice Onshore Facilities (Excluding Oil Production) Page 12 of 14

		PLAN.	FIELD
(7)	Leakage through defective internal heating coils controlled:		
	Steam returns and exhaust lines from internal heating coils that discharge into an open watercourse are monitored for contamination, OR	Yes No MA	Yes No WANA
	Steam returns and exhaust lines pass through a settling tank, skimmer, or other separation or retention system	Yes No NA	Yes No ZNA
(8)	Each container is equipped with at least one of the following for liquid level sensing:	Yes No NA	☑Yes ☐No ☐NA
	signal at a constantly attended operation or and pumping stati	code signal communication tion;	between container gauger
	tacilities; computers, telepu	vstem for determining liquid le	and a person present to
		and overall filling of bulk cont uid level sensing devices to e	
(9)	Effluent treatment facilities observed frequently enough to detect possible system upsets that could cause a discharge as described in §112.1(b)	Yes No NA	Yes No NA
(<u>1</u> 0)	Visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts are promptly corrected and oil in diked areas is promptly removed	Yes No NA	Yes No NA
(11)	Mobile or portable containers positioned to prevent a discharge as described in §112.1(b).	Yes No NA	
	Mobile or portable containers (excluding mobile refuelers and other non-transportation-related tank trucks) have secondary containment with sufficient capacity to contain the largest single compartment or container and sufficient freeboard to contain precipitation	Yes No NA	Yes No NA
112.8(d)/112.12	2(d)Facility transfer operations, pumping, and facility process		
(1)	Buried piping installed or replaced on or after August 16, 2002 has protective wrapping or coating	Yes No NA	Yes No NA
	Buried piping installed or replaced on or after August 16, 2002 is also cathodically protected or otherwise satisfies corrosion protection standards for piping in 40 CFR part 280 or 281	✓ Yes ☐ No ☐ NA	Yes No NA
	Buried piping exposed for any reason is inspected for deterioration; corrosion damage is examined; and corrective action is taken	Yes No NA	
(2)	Piping terminal connection at the transfer point is marked as to origin and capped or blank-flanged when not in service or in standby service for an extended time	Yes No NA	Yes No NA
(3)	Pipe supports are properly designed to minimize abrasion and corrosion and allow for expansion and contraction	Yes No NA	Yes No NA
(4)	Aboveground valves, piping, and appurtenances such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces are inspected regularly to assess their general condition	Yes No NA	Yes No NA
Was .	Integrity and leak testing conducted on buried piping at time of installation, modification, construction, relocation, or replacement	Yes No NA	Yes No NA
(5)	Vehicles warned so that no vehicle endangers aboveground piping and other oil transfer operations	Yes No NA	
Comments:			

ATTACHMENT B: SPCC INSPECTION AND TESTING CHECKLIST

Required Documentation of Tests and Inspections

Records of inspections and tests required by 40 CFR part 112 signed by the appropriate supervisor or inspector must be kept by all facilities with the SPCC Plan for a period of three years. Records of inspections and tests conducted under usual and customary business practices will suffice. Documentation of the following inspections and tests should be kept with the SPCC Plan.

	Documentation		Not	
	Inspection or Test	Present	Not Present	Not Applicable
112.7-Gener	al SPCC Requirements			
(d)	Integrity testing for bulk storage containers with no secondary containment system and for which an impracticability determination has been made			Ø
(d)	Integrity and leak testing of valves and piping associated with bulk storage containers with no secondary containment system and for which an impracticability determination has been made			Ø
(h)(3)	Inspection of lowermost drain and all outlets of tank car or tank truck prior to filling and departure from loading/unloading rack			Ø
(1)	Evaluation of field-constructed aboveground containers for potential for brittle fracture or other catastrophic failure when the container undergoes a repair, alteration, reconstruction or change in service or has discharged oil or failed due to brittle fracture failure or other catastrophe			Ø
k(2)(i)	Inspection or monitoring of qualified oil-filled operational equipment when the equipment meets the qualification criteria in §112.7(k)(1) and facility owner/operator chooses to implement the alternative requirements in §112.7(k)(2) that include an inspection or monitoring program to detect oil-filled operational equipment failure and discharges			Ø
112.8/112.12	-Onshore Facilities (excluding oil production facilities)			
(b)(1), (b)(2)	Inspection of storm water released from diked areas into facility drainage directly to a watercourse	Ø		
(c)(3)	Inspection of rainwater released directly from diked containment areas to a storm drain or open watercourse before release, open and release bypass valve under supervision, and records of drainage events	Ø		. 🗖
(c)(4)	Regular leak testing of completely buried metallic storage tanks installed on or after January 10, 1974 and regulated under 40 CFR 112			O
(c)(6)	Regular integrity testing of aboveground containers and integrity testing after material repairs, including comparison records			Ø
(c)(6), (c)(10)	Regular visual inspections of the outsides of aboveground containers, supports and foundations	Ø		
(c)(6)	Frequent inspections of diked areas for accumulations of oil	Ø		
(c)(8)(v)	Regular testing of liquid level sensing devices to ensure proper operation	V		
(c)(9)	Frequent observations of effluent treatment facilities to detect possible system upsets that could cause a discharge as described in §112.1(b)	Ø		
(d)(1)	Inspection of buried piping for damage when piping is exposed and additional examination of corrosion damage and corrective action, if present			Ø
(d)(4)	Regular inspections of aboveground valves, piping and appurtenances and assessments of the general condition of flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces	Ø	ם	0
(d)(4)	Integrity and leak testing of buried piping at time of installation, modification, construction, relocation or replacement			

U.S. EPA Facility Response Plan (FRP) -- Review Form

I. Facility Information			
FRP Number: FRP-06-TX-00155	Facility Name:	Houston Refinery	
Facility Owner: Valero Refining - Texal LP			
Facility Operator (if different from owner): same			
Mailing Address: PO Box 5038			
City: Houston	State: TX		Zip: 77262-5038
Telephone:713-923-3506		Fax: 713-923-3505	
Latitude: 29.718889	Longitude: -95	.253889	
Other Description or Directions:			
Site Location Map Attached (Y/N): N			

INSPECTION ACKNOWLEDGMENT		
I performed an FRP inspection at the facility specified above.		
INSPECTOR SIGNATURE:	DATE:	
SUPERVISOR REVIEW/SIGNATURE:	DATE:	

II. Facility	Overviev	٧			
Date of Initia	al Facility Op	eration:	1940 and	1942 - they give 2 dates	in different places
Total Storag	e Capacity (I	obls/gals):		209,229,464 gal # Of Tanks: 115	
Worst Case	Discharge (b	obls/gals):		12,600,000 gal	
		narge (barrels rge Workshee			(300,000 barrels)
Actual Worst Case Discharge (gallons) calculated from Worst Case Discharge Worksheet		(12,600,000 gallons)			
Capacity of I	Largest Abov	re Ground Sto	orage Tank (bb	ols/gals): 12,600,000 gal	
	ected Waten ip Channel, S		ted Waterway	(s)/Environmentally Sens	sitive Area (A):
Distance fro	m Facility: 0	- 1/4 mile			
Response C	contractor(s):	Clean Chan	nel Assoc.; Ga	rner Environ.; National F	Response Corp; Phoenix Pollution
Yes	No				
X		Standard Re	sponse Plan (Cover Sheet Submitted w	vith Plan.

	Emergency Response Action Plan Submitted with Plan or as Separate Part of Plan.	,
X		
<u> </u>		
х	Facility Response Plan Follows 40 CFR 112 Appendix F Format.	

.

•

• .

•

: :

III. FRP	Applicability [40 CFR 112.20 (f)(1)]
YES	The facility transfers oil over water to or from vessels and has a total oil storage capacity greater or equal to 42,000 gallons.
-	-OR-
NO	The facility's total oil storage is greater than or equal to 1 million gallons, and one of the following is true:
NO	The facility does not have secondary containment for each aboveground storage area sufficiently large to contain the capacity of the largest aboveground oil storage tank within each storage area plus sufficient freeboard to allow for precipitation.
YES	The facility is located at a distance such that a discharge from the facility could cause injury to fish and wildlife and sensitive environments.
NO	The facility is located at a distance such that a discharge from the facility would shut down a public drinking water intake.
NO	The facility has had a reportable spill in an amount greater than or equal to 10,000 gallons with in the last 5 years.
	Substantial Harm Facility x Significant and Substantial Harm Facility

NOTE: The following checklist items correspond to the final regulations as outlined in 40 CFR 112.20, Appendix F. For all checklist items, indicate FRP adequacy as follows: adequately addressed (YES), deficient or not addressed (NO), or not applicable (N/A).

Facility Response Plan Plan Review Checklist For Verifying Compliance with Facility Response Plan Requirements

Activity In	form	ation	
Activity Type		FRP Plan Review	Clean Channel Assoc 1 hr.; Garner Environ. 1 hr; National Response Corp 1hr; Phoenix Pollution 1 hr
Reason for Review		Initial Plan Submittal (new FRP)	
		5-year Review	
		Plan Amendment (note type)	
	×	Other (note other reason)	
		Note: Inspection	
Activity Date			
EPA Inspector		Chris Perry	

112.20(h)(11)	A. Response Plan Cover Sheet (sec. 2.0)	YES	NO	N/A
	General Information (sec 2.1)			
	Facility name	×		
	Facility address	x		-
····	Facility telephone number	x		
	Mailing address (if different from facility address)	x		
	Facility owner/operator and address (recommended)	×		
	Facility owner telephone (recommended)	×		
	Dun & Bradstreet number	×		
	Longitude (degrees, minutes, seconds)	×		
	Latitude (degree, minutes, seconds)	×		
	North American Industrial Classification System (NAICS) code	x		
	Facility start up date (recommended)	X		
	Facility acres (recommended)	×		
	Name of protected waterway or environmentally sensitive area	- X		
	Distance to navigable water	T x		
	Worst case discharge amount (gallons)	×		
	Maximum oil storage capacity (gallons)	×		
	Largest aboveground storage tank (AST) capacity (gallons)			
	Total number of ASTs	X		
	Total number of underground storage tanks (USTs)			×
	Total UST storage		 	×
	Total storage of drums and transformers that contain oil	х		

Plan Review Checklist Page 1/14

B. Emergency Response Action Plan (ERAP) (sec. 1.1)	YES	NO	N/A
Separate Section of FRP	х		
Qualified Individual (QI) Information (sec. 1.2)	х		
Emergency Notification List (sec. 1.3.1)	х		-
Spill Response Notification Form (sec. 1.3.1)	х		
Response Equipment List and Location (sec. 1.3,2)	х		
Response Equipment Testing and Deployment (sec. 1.3.4)	х		
Facility Response Team List (sec. 1.3.4)	×		
Evacuation Plan (sec. 1.3.5)	x		
Immediate Actions (sec. 1.7.1)	х		
Facility Diagrams (sec. 1.9)	х		
*The sections above should be extracted from the more detailed corresp	onding section	ns of the	plan.
	Separate Section of FRP Qualified Individual (QI) Information (sec. 1.2) Emergency Notification List (sec. 1.3.1) Spill Response Notification Form (sec. 1.3.1) Response Equipment List and Location (sec. 1.3.2) Response Equipment Testing and Deployment (sec. 1.3.4) Facility Response Team List (sec. 1.3.4) Evacuation Plan (sec. 1.3.5) Immediate Actions (sec. 1.7.1) Facility Diagrams (sec. 1.9)	Separate Section of FRP Qualified Individual (QI) Information (sec. 1.2) Emergency Notification List (sec. 1.3.1) X Spill Response Notification Form (sec. 1.3.1) Response Equipment List and Location (sec. 1.3.2) Response Equipment Testing and Deployment (sec. 1.3.4) Facility Response Team List (sec. 1.3.4) Evacuation Plan (sec. 1.3.5) Immediate Actions (sec. 1.7.1) Facility Diagrams (sec. 1.9)	Separate Section of FRP Qualified Individual (QI) Information (sec. 1.2) Emergency Notification List (sec. 1.3.1) X Spill Response Notification Form (sec. 1.3.1) Response Equipment List and Location (sec. 1.3.2) Response Equipment Testing and Deployment (sec. 1.3.4) Facility Response Team List (sec. 1.3.4) Evacuation Plan (sec. 1.3.5) Immediate Actions (sec. 1.7.1) X

Notes: Items marked in red are not included in this section of the plan.

112.20(h)(2)	C. Facility Information (sec. 1.2)	YES	NO	N/A
	Facility name (sec. 1.2.1)	х		
	Street address	X		
	City, state, zip code	х		
	County	x		
	Phone number	х	-	
······································	Latitude/longitude (sec. 1.2.2)	х		
	Wellhead protection area (sec. 1.2.3)	х		
	Owner/operator (both names included, if different) (sec. 1.2.4)	x		
··· ·· · · · · · · · · · · · · · · · ·	QI Information (sec. 1.2.5)	×		

Plan Review Checklist Page 2/14

-Name, position, street address, phone numbers	х	
- Description of specific response training experience	х	
Oil storage start-up date (sec. 1.2.6)	x	
Facility operations description (sec. 1.2.7)	x	
North American Industrial Classification System (NAICS) or Standard Industrial Classification code (SIC)	х	

Plan Review Checklist Page 3/14

	Dates and types of substantial expansion (sec. 1.2.8)	х	1 .	_
Notes:				
	!			

Notification (sec. 1.3.1) Emergency Notification Phone List National Response Center phone number QI (day and evening) phone numbers Company response team (day and evening) phone numbers Federal On-Scene Coordinator (OSC) and/or Regional Response Center (day and evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number State Emergency Response Commission (SERC) phone number	x x x x x x		
National Response Center phone number QI (day and evening) phone numbers Company response team (day and evening) phone numbers Federal On-Scene Coordinator (OSC) and/or Regional Response Center (day and evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s)	x x x x		
QI (day and evening) phone numbers Company response team (day and evening) phone numbers Federal On-Scene Coordinator (OSC) and/or Regional Response Center (day and evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number	x x x x		
Company response team (day and evening) phone numbers Federal On-Scene Coordinator (OSC) and/or Regional Response Center (day and evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number	x x x		
Federal On-Scene Coordinator (OSC) and/or Regional Response Center (day and evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number	x x x		
evening) phone numbers Local response team phone numbers (fire department/cooperatives) Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number	x x		
Fire marshal (day and evening) phone numbers State emergency response phone number(s) State Police phone number	х		
State emergency response phone number(s) State Police phone number			i
State Police phone number	х		
1			
State Emergency Personne Commission (SEPC) phone number	x '		
State Emergency Response Commission (SERC) phone number	X		
Local emergency planning committee (LEPC) phone number	X		
Wastewater treatment facility(s) name and phone number (recommended)	х		
Local water supply system (day and evening) phone numbers	_		
Weather report phone number	x		
Local television/radio phone number(s) for evacuation notification	х		
Spill response contractor(s)	х		
Factories/Utilities with water intakes (recommended)			Х
Trustees of sensitive areas (recommended)			X
Hospital phone number	Х		
Spill Response Notification Form			
Reporter's name, position and phone number	х		
Company information	х		
Incident description (source/cause)	х		
Material (were materials discharged?)	х		
Response action (meeting federal obligations to report, calling for responsible party, time called)	х		
Impact :	×		
Date/time of incident, incident address/location, rearest city/state/county/zip code, distance from city/units of measure/direction from city, township, range, borough, container type/tank oil storage capacity	x		
Units of measure, facility oil storage capacity/units of measure, facility longitude and latitude	х		
	Local water supply system (day and evening) phone numbers Weather report phone number Local television/radio phone number(s) for evacuation notification Spill response contractor(s) Factories/Utilities with water intakes (recommended) Trustees of sensitive areas (recommended) Hospital phone number Spill Response Notification Form Reporter's name, position and phone number Company information Incident description (source/cause) Material (were materials discharged?) Response action (meeting federal obligations to report, calling for responsible party, time called) Impact Date/time of incident, incident address/location, nearest city/state/county/zip code, distance from city/units of measure/direction from city, township, range, borough, container type/tank oil storage capacity Units of measure, facility oil storage capacity/units of measure, facility longitude and	Wastewater treatment facility(s) name and phone number (recommended) Local water supply system (day and evening) phone numbers X Weather report phone number Local television/radio phone number(s) for evacuation notification X Spill response contractor(s) Factories/Utilities with water intakes (recommended) Trustees of sensitive areas (recommended) Hospital phone number X Spill Response Notification Form Reporter's name, position and phone number Company information Incident description (source/cause) Material (were materials discharged?) Response action (meeting federal obligations to report, calling for responsible party, time called) X Date/time of incident, incident address/location, nearest city/state/county/zip code, distance from city/units of measure/direction from city, township, range, borough, container type/tank oil storage capacity Units of measure, facility oil storage capacity/units of measure, facility longitude and	Wastewater treatment facility(s) name and phone number (recommended) Local water supply system (day and evening) phone numbers X Weather report phone number Local television/radio phone number(s) for evacuation notification X Spill response contractor(s) Factories/Utilities with water intakes (recommended) Trustees of sensitive areas (recommended) Hospital phone number X Spill Response Notification Form Reporter's name, position and phone number Company information X Incident description (source/cause) Material (were materials discharged?) Response action (meeting federal obligations to report, calling for responsible party, time called) Impact Date/time of incident, incident address/location, nearest city/state/county/zip code, distance from city/units of measure/direction from city, township, range, borough, container type/tank oil storage capacity Units of measure, facility oil storage capacity/units of measure, facility longitude and

Plan Review Checklist Page 4/14

Plan Review Checklist Page 5/14

112.20(h)(1)(iv), 112.20(h)(3)(vi)	Response Equipment (sec 1.3.2)	YES	NO	N/A
	Equipment Information		·	
	Equipment list	×		
	Equipment location	x	· · · · · · · · · · · · · · · · · · ·	
	Release handling capabilities and limitations (e.g., launching sites)	х		
Notes:		L	L	

112.20(h)(3)(vi)	E. Response Equipment List (Identify if Facility, OSRO, CO-OP owned by letters O, F, or C) (sec. 1.3.2)	YES	NO	N/A
	Skimmers/pumps (operational status, type/model/year, number or quantity, capacity, daily effective recovery rate, storage location)	0		
2000' 18" Boom	Boom (containment boom: operational status, year, number, skirt size)	F		
27 Bags (5 per) Oil only sock boom; 40 bags of pads Polypropylene Oil Sorbend Pads; Soda	Boom (sorbent boom: operational status, type/model/year, number, size (length))	F		
	Chemical countermeasure agents stored	0		
	Sorbents (type, year purchased, amount, storage location)	0		
	Hand tools (type, quantity, storage location)	0		
1w/ 15 Towers Alarm/PA; 50 Cellular	Communications equipment (operational status, type and year, quantity, storage location)	F		
Hand tools, various at the Fire Station on the Engine; Assosrted PPE (HAZ-Mat Trailer)	Fire Fighting and Personnel Protective Equipment	F		
(Fire Station)	Boats and Motors (operational status, type, and year, quantity, storage location)	F		
10 boxes Colorimetric Tuber; 23 Multi-Gas Meters	Other (e.g., heavy equipment, cranes, dozers, etc.) (operational status, type and year, quantity, storage location)	F		
	Equipment Location	×		
	Amount of oil that emergency response equipment can handle and limitations (e.g., launching sites) must be described.	х		
Notes:				

112.20(h)(8)(i) and (ii)	F. Response Equipment Testing and Deployment Drill Log (sec. 1.3.3)	YES	NO	N/A
	Date of last inspection or equipment test	х		
	Inspection Frequency	Х		Ï
	Date of Last Deployment	х		
	Deployment Frequency	х		

Plan Review Checklist Page 6/14

	OSRO Certification (Note: Facilities without facility owned response equipment must ensure that the Oil Spill Removal Organization that is identified in the response plan to provide this response equipment certifies that the deployment exercises have been met)	x	
Notes:			
			- 1

	G. Personnel (sec. 1.3.4)	YES	NO	N/A
112.20(h)(3)(v), 112.20(h)(1)(v)	Emergency Response Personnel Information (Personnel whose duties involve resincluding oil discharges, even when they are not present at the site)	ponding	to emerg	encies
	Response personnel name(s)	Х		
	Facility response team title/position	Х		
	Response personnel phone numbers (work/home, other)	х		
	Response personnel response time	Х		
	Response personnel responsibility	х		
	Response personnel training (type and date)		x	
- <u>-</u>	Emergency Response Contractor Information			
12.20(h)(3)(i)	· ·			
	Response contractor name (s)	Х		
	Response contractor phone numbers	X		
	Response contractor response time	X		
112.20(h)(3)(ii)	Response contractor evidence of contractual arrangements	Χ,		
	Facility Response Team Information (Composed of Emergency Response Personn Response that will respond immediately)	el and E	mergenc	y
	Response team member name(s)	х		
· · · · · · · · · · · · · · · · · · ·	Response team member job function	X	1	
	Response team member response time	Х		
	Response team member phone/pager number	X	/	
	Name of emergency response contractor (contractors providing facility response team services may be different than contractors providing oil spill response services)	x		
	- Response time	X		
	- Phone/pager	Х	1	
	Cacilif response team (Boon)			

112.20(h)(1)(vi). H. Evacuation Plans (sec. 1.3.5)

112.20(h)(1)(vi), 112.20(h)(3)(vii)	H. Evacuation Plans (sec. 1.3.5)	YES	IO N/A
	Facility Evacuation Plan (sec. 1.3.5.1)	/	
	Location of stored materials		x
	Hazard imposed by spilled materials		x

	Spill flow direction	x	
	Prevailing wind directions and speed	х	
**************************************	Water currents, tides, or wave conditions (if applicable)	х	
	Arrival route of emergency response personnel and response equipment	х	
	Evacuation routes	x	
	Alternative routes of evacuation	*	\
	Transportation of injured personnel to nearest emergency medical facility	(x)	7
	Location of alarm/notification systems	X	
	Centralized check-in area for roll call	x	
	Mitigation command center location	х	
	Location of shelter at facility	х	
112.20(h)(3)(vii), 112.20(h)(1)(vi)	Community Evacuation Plans referenced (sec. 1.3.5.3)	(x)	
Notes: The Evacuat	ion Plan should include a written discussion of each of the items marked in red above		
	!		
	i i		

112.20(h)(3)(ix)	I. Qualified Individual's Duties (sec. 1.3.6)	YES	NO	N/A
112.20(h)(3)(ix)(A)	Activate internal alarms and hazard communication systems	х		
112.20(h)(3)(ix)(B)	Notify Response Personnel	х		
112.20(h)(3)(ix)(C)	Identify character, exact source, amount, and extent of the release	Х		
112.20(h)(3)(ix)(D)	Notify and provide information to appropriate Federal, State and local authorities	×		
112.20(h)(3)(ix)(E)	Assess interaction of spilled substance with water and/or other substances stored at facility and notify on-scene response personnel of assessment	×		
112.20(h)(3)(ix)(F)	Assess possible hazards to human health and the environment	х		
112.20(h)(3)(ix)(G)	Assess and implement prompt removal actions	х		
112.20(h)(3)(ix)(H)	Coordinate rescue and response actions	х		
112.20(h)(3)(ix)(l)	Access company funding to initiate cleanup activities	X		
112.20(h)(3)(ix)(J)	Direct cleanup activities	Х		
Notes:				
	t }			

J. Hazard Evaluation (sec. 1.4) (See Section II, Append	fix A) YES	NO	N/A
Hazard Identification (sec. 1.4.1)	· · · · · · · · · · · · · · · · · · ·		. 1
Tank Above Ground and Below Ground			
Tanks (List Tanks by Number, Product and Shell Capacity in the	space below)		
Tank number(s)	T x		
Substance(s) stored	×		
Quantity(s) stored	x		
	Hazard Identification (sec. 1.4.1) Tank Above Ground and Below Ground Tanks (List Tanks by Number, Product and Shell Capacity in the Tank number(s) Substance(s) stored	Hazard Identification (sec. 1.4.1) Tank Above Ground and Below Ground Tanks (List Tanks by Number, Product and Shell Capacity in the space below) Tank number(s) Substance(s) stored Quantity(s) stored	Hazard Identification (sec. 1.4.1) Tank Above Ground and Below Ground Tanks (List Tanks by Number, Product and Shell Capacity in the space below) Tank number(s) Substance(s) stored Quantity(s) stored

Plan Review Checklist Page 8/14

	Tank type(s)/year(s) of construction	х		
	Shell capacity(s)	х		
	Failure(s)/cause(s)			×
	Surface Impoundments (SI)			·
	SI Number(s)			x
	Substance(s) Stored		 	×
	Quantity(s) Stored		1	×
	Surface area(s)/year(s) of construction		 	×
	Maximum capacity(s)			×
·	Failure(s)/cause(s)		1	l x
	Labeled schematic drawing	×		
	Description of transfers (loading and unloading) and volume of material	${x}$		
<u> </u>	Description of daily operations	×		
	Secondary containment volume(s)	x		
	Normal daily throughput of the facility	\	1	

112.20(h)(4)	K. Vulnerability Analysis (sec. 1.4.2) (See Appendix A - Calculation of the Planning Distance)	e YES	NO	N/A
Planning Distance = 15 miles	Analysis of potential effects of an oil spill on vulnerable areas. (Attachment C-III to provides a method that owners or operators shall use to determine appropriate distand wildlife and sensitive environments. Owners or operators can use a comparabacceptable by the Regional Administrator (RA). If a comparable formula is used, d reliability and analytical soundness of the formula must be attached to the Response	ances from le formula o cumentati	the facil that is co on of the	lity to fisl ensidered
	Water intakes (drinking, cooling or other)	х		
	Schools	x		
	Medical facilities			х
	Residential areas	х		
	Businesses	х		
	Wetlands or other sensitive environments	x		
	Fish and wildlife	х		
, -	Lakes and streams	×	·	
	Endangered flora and fauna	×		
	Recreational areas	×		
	Transportation routes (air, land, and water)	x		
·	Utilities	×		
	Other applicable areas of economic importance (list below)			×
Notes:				<u> </u>

Plan Review Checklist Page 9/14

112.20(h)(4)	L. Analysis of the Potential for an Oil Spill (sec. 1.4.3)	YES	NO	N/A
	Description of likelihood of release occurring	Х		
	Oil spill history for the life of the facility	х		
	Horizontal range of potential spill	х		
	Vulnerability to natural disaster	×		
	Tank age	х		

Plan Review Checklist Page 10/14

	Other factors (e.g., unstable soils, earthquake zones, Karst topography, etc.)	х	·	
Notes:				
	!			
				·

112.20(h)(4)	M. Facility Reportable Oil Spill History Description (sec. 1.4.4)	YES	NO.	N/A
<u>,-</u>	Date of discharge(s)	×		
	List of discharge causes	х		
	Material(s) discharged		х	
	Amount of discharges (gallons)	X		
	Amount that reached navigable waters (if applicable)	1/	Х	
•	Effectiveness and capacity of secondary containment	1		
	Clean-up actions taken		x	
	Steps taken to reduce possibility of recurrence	1/	X	
· · · · · · · · · · · · · · · · · · ·	Total oil storage capacity of tank(s) or impoundment(s) from which material discharged		х	
	Enforcement actions		х	
	Effectiveness of monitoring equipment	1/	х	
	Description(s) of how each oil discharge was detected	1	х	

Notes: Items marked in red are included in this section of the plan.

	N. Discharge Scenarios (sec. 1.5)	YES	NO	N/A
	Small Discharges (sec. 1.5.1) (Description of small discharges addressing faincluding but not limited to (see. 1.5.1.1):	cility operations	and com	ponents
	Loading and unloading operations		х	
	Facility maintenance operation		x	
	Facility piping		х	
	Pumping stations and sumps		х	
-	Oil storage location		х	
	Vehicle refueling operations		х	
	Age and condition of facility components	<u></u>	x	
	Small volume discharge calculation for a facility		х	
	Facility-specific spill potential analysis		x	
	Average most probable discharge for complexes	${x}$		
	1,000 feet of boom (1 hour deployment time)	x		
	Correct amount of boom for complexes	x		
	Oil recovery devices equal to small discharge (2 hour recovery time)	X		
	Oil storage capacity for recovered material	x	<u> </u>	

Plan Review Checklist Page 11/14

	Scenarios Affected by the Response Efforts (sec. 1.5.1.2)			
	Size of the discharge	<u> </u>	T 1	
	Proximity to down gradient wells, waterways, and drinking water intakes	X		
	Proximity to fish and wildlife and sensitive environments	<u> </u>	X	
		 	×	
	Likelihood that the discharge will travel offsite (i.e., topography, drainage)	<u> </u>	X	
	Location of the material discharged (i.e., on a concrete pad or directly on the soil)		x	
	Material discharged		х	
	Weather or aquatic conditions (i.e., river flow)		х	
	Available remediation equipment		х	
	Probability of a chain reaction of failures		×	
	Direction of discharge pathway		×	
	Medium Discharges (sec. 1.5.1) (Description of medium discharges scenarios addrand components including but not limited to (sec. 1.5.1.1):	essing fa	cility oper	ations
	Loading and unloading operations	<u> </u>	х	
	Facility maintenance operation		х	
	Facility piping	<u> </u>	X	
	Pumping stations and sumps		x	
	Oil storage location	 	x	
	Vehicle refueling operations		х	
	Age and condition of facility components	 	X	
	Medium volume discharge calculation for a facility	x		
	Facility-specific spill potential analysis	X		
	Maximum most probably discharge for complexes	X		
	Oil recovery devices equal to medium discharge	 		
	Availability of sufficient quantity of boom	X		
	Oil storage capacity for recovered material	X		
	Scenarios Affected by the Response Efforts (sec. 1.5.1.2)		<u> </u>	-
	Size of the discharge	×		
	Proximity to down gradient wells, waterways, and drinking water intakes	†	x	
	Proximity to fish and wildlife and sensitive environments	<u> </u>	х	
	Likelihood that the discharge will travel offsite (i.e., topography, drainage)	†	X	
	Location of the material discharged (i.e., on a concrete pad or directly on the soil)		х	
	Material discharged	†	х	
	Weather or aquatic conditions (i.e., river flow)	†	x	
	Available remediation equipment		x	
	Probability of a chain reaction of failures	<u> </u>	х	
	Direction of discharge pathway		×	
lotos: Disebarra sess	enerios are too generic. Choose one and write a mock drill from it for each case. Did not	End Ma	<u></u>	

Notes: Discharge sceanarios are too generic. Choose one and write a mock drill from it for each case. Did not find the Scenarios Affected by the Response Efforts mentioned in the plan. Each of these listed must be written into the plan for each scenario.

Plan Review Checklist Page 12/14

112.20(h)(5)(i)	O. Worst Case Discharge (sec. 1.5.2) (See Appendix A) (When planning for the worst case discharge response all of the factors listed in the small and medium discharge section of the response plan shall be addressed)	YES	NO	N/A		
	Facility Specific Worst Case Discharge Scenario	 	х			
	Description of worst case discharges scenarios addressing facility operations including but not limited to (sec. 1.5.1.1):	and com	ponents			
	Loading and unloading operations		х			
	Facility Maintenance Operation		х			
	Facility Piping		х			
	Pumping stations and sumps		х			
	Oil storage location		х			
	Vehicle refueling operations		х			
	Age and condition of facility components		х			
112 Appendix D	Correct Worst Case Discharge (WCD) calculation for specific type of facility	×				
	Correct WCD calculation for complexes	×				
112 Appendix E	Sufficient response resources for WCD	х		•		
	Sources and quantity of equipment for response to WCD	×				
	Oil storage capacity for recovered material	×				
	Scenarios Affected by the Response Efforts (sec. 1.5.1.2)					
	Size of the discharge	×				
	Proximity to down gradient wells, waterways, and drinking water intakes	x				
	Proximity to fish and wildlife and sensitive environments		х			
	Likelihood that the discharge will travel offsite (i.e., topography, drainage)		х	,		
	Location of the material discharged (i.e., on a concrete pad or directly on the soil)		х			
	Material discharged		х			
	Weather or aquatic conditions (i.e., river flow)		х			
	Available remediation equipment		х			
	Probability of a chain reaction of failures	<u> </u>	х			
	Direction of discharge pathway	1	х	-		

Notes: Discharge sceanarios are too generic. Choose one and write a mock drill from it for each case. Did not find the Scenarios Affected by the Response Efforts mentioned in the plan. Each of these listed must be written into the plan for each scenario.

112.20(h)(6)	P. Discharge Detection Systems (sec. 1.6)	YES	NO	N/A
	Discharge Detection by Personnel (sec. 1.6.1)	•	•	•
	Description of procedures and personnel for spill detection	x	ŧ	
	Description of facility inspections	x		
	Description of initial response actions		₩.	

Plan Review Checklist Page 13/14

	Emergency Response Information (referenced)		X	
Notes: Items marked in	red are not included in this section of the plan.			•
	in plan			
Section II, 112.7(e)(5)(iii)(D), 112.7(e)(5(iii), 112.7(e)(2)(viii), 112.7(e)(7)(v), Appendix A	Automated Discharge Detection (sec. 1.6.2)			
	Description of automatic spill detection equipment, including overfill alarms and secondary containment sensors	x		
	Description of alarm verification procedures and subsequent actions	×		
	Initial response actions	V	*	
Notes: Items marked in	red are not included in this section of the plan.			
	in glan			

112.20(h)(7), Appendix E	Q. Plan Implementation (sec. 1.7)	YES	NO	N/A
	Identification of response resources for small, medium, and worst case spills (sec. 1.7.1)	
	Description of response actions	X		[
	Accessibility of proper response personnel and equipment	×		
,	Emergency plans for spill response	x		· · · · · · · · · · · · · · · · · · ·
	Additional response training	X		
	Additional contracted help	X		
	Access to additional response equipment/experts	x	-	
	Ability to implement plan, including response training and practice drills	x		
	Temporary storage	x	• •	
	Recommended form detailing immediate action for small, medium and Worst Case spills (sec. 1.7.1.2A) (stop the product flow, warn personnel, shut off ignition sources, initiate containment, notify NRC, notify OSC, notify (as appropriate))	. х		
Notes:				
	Disposal Plan (sec. 1.7.2)		·	
	Description of procedures for recovering, reusing, decontaminating or disposing of materials	x		
	Materials addressed in Disposal Plan (recovered product, contaminated soil, contaminated equipment and materials (including drums tank parts, valves and shovels), personnel protective equipment, decontamination solutions, absorbents, spent chemicals)	x		
	Plan prepared in accordance with any federal, state, and/or local regulations	х		
	Plan addresses permits required to transport or dispose of recovered materials		х	

Plan Review Checklist Page 14/14

Notes: Items marked in	red are not included in this section of the plan. Add a More destribed discussion of the plan. Oes to onsite RCKA yord por facility of Containment and Drainage Planning (Sec. 1.7.3)	of how	all
Section II, 112.7(e)(1), 112.7(e)(7), Appendix A	Containment and Drainage Planning (sec. 1.7.3)		
	Description of containing/controlling a spill through drainage	x	
	Containment and drainage plan available	×	
	Available volume of containment	x	
	Drainage route from oil storage and transfer areas	×	
	Construction materials used in drainage troughs	×	
	Type and number of valves and separators in drainage system	×	
	Sump pump capacities	x	
	Containment capacities of weirs and booms and their location		X
	Other cleanup materials	×	
Notes:		<u> </u>	

	R. Self-Inspection, Training, and Meeting Logs (sec. 1.8)	YES	NO	N/A
	Facility Self-Inspection (sec. 1.8.1)			
Section II, 112.7(e)(8)	Records of tank inspections with dates (tank leaks, tank foundations, tank Piping) contained or cross-referenced in Plan or maintained electronically for five years	х		
Section II, 112.7(e)(8)	Records of secondary containment inspections with dates (dike or berm system, secondary containment, retention and drainage ponds) contained or cross-referenced in Plan or maintained electronically for five years	. X		
112.20(h)(8)(i)	Response equipment inspection		· · · · · · · · · · · · · · · · · · ·	
	Response equipment checklist (sec. 1.8.1.2)	х		
	Equipment inventory (item and quantity)	х		
	Storage location (time to access and respond)	х		
	Accessibility (time to access and respond)	х		
	Operational status/condition	х		
	Actual use/testing (last test date and frequency of testing)	х		
	Shelf life (present age, expected replacement date)	X		
	- Inspection date	X		
	- Inspector's signature	X		
	- Inspection records maintained for 5 years	x		
· · · · · · · · · · · · · · · · · · ·	- Response equipment inspection log (inspector, date, comments)	Х		
Notes:				
	Facility Drills/Exercises (sec. 1.8.2)	_		
	Description of drill/exercise program based on National Preparedness for Response Exercise Program (PREP) guidelines or other comparable program	х		

Plan Review Checklist Page 15/14

	If "no" alternative program has been approved by EPA RA (describe program below)		
	QI notification drill	х	
	Spill management team tabletop exercise	х	
	Equipment deployment exercise	x	
	Unannounced exercise	х	
	Area exercise	х	
	Description of evaluation procedures for drill program	х	
	Qualified Individual notification drill log (sec. 1.8.2.1)		
	Date, company, qualified individual, other contacted, emergency scenario, evaluation	×	•
	Spill management team tabletop drill log (sec. 1.8.2.2)		
	Date, company, QI, participants, emergency scenario, evaluation, changes to be implemented, time table for implementation	х	
Notes:	PREP Drills Are Good		
	Response Training (sec. 1.8.3)		
	Description of response training program (including topics)	x	
	Personnel response training logs (name, response training date/and number of hours, prevention training date/and number of hours)	x	
	Discharge prevention meeting logs (date, attendees)	х	
Notes:	·	•	

	S. Diagrams (sec. 1.9)	YES	NO	N/A
	Site Plan Diagram			
	Entire facility to scale	х		
	Above and below-ground storage tanks	x	<u> </u>	
	Contents and capacities of bulk oil storage tanks	×		
	Contents and capacities of drum storage areas	×	l	
	Contents and capacities of surface impoundments			x
	Process buildings	×		
	Transfer areas	X		
	Location and capacity of secondary containment systems	х		
	Location of hazardous materials	х		
	Location of communications and emergency response equipment	×		
	Location of electrical equipment that might contain oil	×	** ***	
	If the facility is a complex facility, the interface between EPA and other regulating agencies	х		
Notes:			<u> </u>	
	Site Drainage Plan Diagram			
	Site Drainage Plan Diagram			

Plan Review Checklist Page 16/14

	Major sanitary and storm sewers, manholes, and drains	х	(
	Weirs and shut-off valves			х
	Surface water receiving streams	х		
	Fire fighting water sources	х		
	Other utilities	х		
	Response personnel ingress and egress	х		
	Response equipment transportation routes	х		
	Direction of spill flow from discharge points	x		. '
Notes:				
	Site Evacuation Plan Diagram			
	Site plan diagram with evacuation routes	х		
	Location of evacuation regrouping areas	х		
Notes:				
Section II, 112.7(e)(9)	T. Site Security (sec. 1.10)	YES	NO	N/A
	Description of facility security	x		
	(Emergency cut-off locations, enclosures, guards and their duties, lighting, valve and pump locks, pipeline connection caps)	×		
Motor				-

Please use the following space to describe overall impressions of the facility response plan (i.e., functional, workable). A set of questions is provided in Appendix C to assist the inspector is assessing overall Plan adequacy.						
Reviewed by:	Karen A. Sterrett					
Date:	3/22/2017					

Plan Review Checklist Page 17/14